

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20173611, Public Works Infrastructure Permit - Commercial

Village at View High On-Site Infrastructure

Address: 3390 NW VILLAGE PARK DR, LEES SUMMIT, MO 640813391 NW VILLAGE PARK DR, LEES SUMMIT, MO 64081245 NW KESSLER DR, LEES SUMMIT, MO 64081201 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Erosion Sediment Control (ESC) Inspection	Steve Robbins	Partial	Wednesday, February 21, 2018

Informational

1 The silt fence is up and in good condition. Steve Robbins 01/26/2018 1:39 PM

Informational

2 The silt fence is up and in place. I walked the entire site with the contractor for off-site sanitary. Steve Robbins 01/31/2018 2:49 PM

Informational

3 The silt fence is still up and after the rain is still in good condition. I did not see any run-off. Steve Robbins 02/21/2018 11:56 AM

Comments: