

**PUBLIC WORKS ENGINEERING DIVISION**

## Inspection Summary

Permit #: PRPWFR20171953, Public Works Infrastructure Permit - Residential  
Manor at Stoney Creek 2nd plat - County Line Rd improvements

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

<b>Inspection:</b>	<b>Inspector:</b>	<b>Outcome:</b>	<b>Date:</b>
DEI-Street - Striping	Brice Lawson	Passed	Wednesday, February 21, 2018

Informational

1 Brice Lawson 02/21/2018 2:38 PM

It appears that the existing double yellow lines and diagonal striping that was proposed to be removed has been removed.

Jeremy with K & G Striping let me know that high build paint was used for the new white and yellow striping. The two new arrows have been installed in the turn lane.

A 12' lane width was not achieved as shown on the plans. I spoke to Kent about the lane widths not being 12' as shown on plans and he thought it would be fine. I explained that the new lane widths are close the the existing lane widths that are east of Alabaster. The plans show a proposed taper length of 150'. The taper has been installed approx. 210' in length.

**Comments:**