
PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRRES20170717, Building Permit - Residential

Address: 3344 SW JESSIE LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

| Inspection: | Inspector: | Outcome: | Date: |
|---------------------|-------------------|-----------------|-----------------------------------|
| Driveway Inspection | Jeremy Young | Passed | Thursday, February 22, 2018 |

Informational

- 1 Jeremy Young 02/22/2018 2:47 PM Contractor has poured the driveway for the residence. The expansion joint is in place and it appears the driveway was poured at least 6" thick. The residence will have a sidewalk at a later time. I checked the cross slope for ADA compliance. The cross slope where the sidewalk will go is under 1.5% throughout the driveway.

Comments:
