

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20172360, Building Permit - Commercial

Address: 300 SW BLUE PKWY, Unit:A, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Partial	Friday, February 23, 2018

Corrective Action Required

1	Misc	- ROOFTOP GAS PIPING PIPING BLOCKS NOT COMPLETED AT UNITS. STACKED BLOCKS MUST BE FASTENED TOGETHER. WOOD BLOCKS IN CONTACT WITH ROOF MEMBRANE MUST HAVE SLIP SHEETS SCREWED TO SIDES OF BLOCKS. - ROOFTOP GAS PIPE NOT PAINTED 100% - CLEAN <u>ALL</u> DEBRIS OFF ROOF
---	------	---

Corrective Action Required

2	Misc	ELECTRICAL SERVICE PERMANENT CONFIGURATION TO BE COMPLETED AND APPROVED.
---	------	--

Corrective Action Required

3	Misc	OBTAIN FINAL APPROVAL FROM: - LS WATER DEPARTMENT - LS FIRE DEPARTMENT
---	------	--

Corrective Action Required

4	Misc	OK TO SET UP FOR BUSINESS. NO PUBLIC ENTRY OR BUSINESS OPERATIONS PRIOR TO APPROVAL.
---	------	---

Occupancy Inspection - Fire	Michael Weissenbach	Partial	Friday, February 23, 2018
------------------------------------	---------------------	---------	---------------------------

Comments: