

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20172441, Building Permit - Residential

Address: 4721 NE GATEWAY DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Monday, February 26, 2018

Corrective Action Required

1 Misc

FRAMING:

-Support deck beam at house side

**check later

-At return air at front bed, fireblock wall space from roof

-Fb basement wall from furdownd space at east closet

-Brace beam under gable wall along front-back bedrooms

**brace the beam from rotation at bearing walls

-Provide full support under I beam and lvl point loads

**Look carefully where the point loads are and provide solid support underneath

**OK TO INSULATE

Comments: