

**PUBLIC WORKS ENGINEERING DIVISION**

## Inspection Summary

Permit #: PRPWFR20171420, Public Works Infrastructure Permit - Residential  
CREEKSIDE AT RAINTREE

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

| Inspection:                   | Inspector:   | Outcome: | Date:                           |
|-------------------------------|--------------|----------|---------------------------------|
| DEI-Sanitary Sewer - Air Test | Brice Lawson | Partial  | Monday,<br>February 26,<br>2018 |

Informational

1 Brice Lawson 02/15/2018 5:10 PM

The following sanitary line segments were are tested:

MH 1-A1 to MH 1-A2

Start 4 psi

End 4 psi

Test Duration 7:34

Test Passed

MH 1-A2 to MH 1-A3

Start 4 psi

End 3.95 psi

Test Duration 7:34

Test Passed

MH 1-A3 to MH 1-A4

Start 4 psi

End 3.9

Test Duration 7:37

Test Passed

Informational

2 Brice Lawson 02/15/2018 5:20 PM

The following sanitary line segments were air tested:

MH 1-A4 to MH 1-B1

Start 4.0 psi

End 3.95 psi

Test Duration 7:34

Test Passed

MH 1-A4 to MH 1-A5

Start 4.0 psi

End 3.9 psi

Test Duration 7:34

Test passed

Informational

3 Brice Lawson 02/23/2018 3:46 PM

The following line segments have been tested.

MH 1-A5 to MH 1-A6

Test Start 3.95 psi

Test End 3.95 psi

Test Duration 7:34

Test Passed

MH 1-A6 to MH 1-A7

Test Start 3.95 psi

Test End 3.95 psi

Test Duration 7:34

Test Passed

Informational

4 Brice Lawson 02/26/2018 11:00 AM

The air test was performed on the 8" PVC line segment from existing City MH 64-003 to MH 1-A1.

Test Start: 3.8 psi

Test Ended at 3.8 psi

Test Duration 7:34 min.

Test Passed

**Comments:**

---