

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20172113, Public Works Infrastructure Permit - Commercial

B&B Theatre

Address: 3201 SW FASCINATION DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Sanitary Sewer Construction Inspection	Steve Robbins	Partial	Monday, February 26, 2018

Informational

1 The camera test has passed from the water dept. but there is debris in the line and needs to be flushed again before it will pass. Steve Robbins 12/27/2017 2:40 PM

Corrective Action Required

2 I called the contractor to let them know they need to flush the line again. Steve Robbins 01/23/2018 9:44 AM

Corrective Action Required

3 I spoke with the contractor and they will flush the sanitary line when the weather breaks. Steve Robbins 02/05/2018 1:40 PM

Corrective Action Required

4 I spoke with the contractor and they will be here on thursday to flush the sanitary line. Steve Robbins 02/26/2018 11:38 AM

Comments: