



STAND Structural Engineering Inc
11827 W. 112th St.
Overland Park, KS 66210
(913) 424-9115

Date: 9/15/2016
To: Mr. Bill Barnard
From: Paul W. Spears, PE
Subject: Tank Excavation
Address: 2751 Douglas Rd, Lee's Summit, MO

Dear Mr. Barnard,

I have reviewed the tank excavation that occurred next to the building at the address listed above. The excavation did not extend below and undermine the footings. Therefore, the current condition is adequate, and no action needs to be taken.

Sincerely,

Paul W. Spears, PE



9/15/16