



STAND Structural Engineering Inc
11827 W. 112th St.
Overland Park, KS 66210
(913) 424-9115

Date: 12/14/2016
To: Mr. Bill Barnard
From: Paul W. Spears, PE
Subject: Anchor Rods
Address: 2751 Douglas Rd, Lee's Summit, MO (Hanger T)

Dear Mr. Barnard,

During construction, we discussed using epoxy anchors in lieu of cast-in anchor rods. This is acceptable and the required embedment depth is 12".

We have reviewed the as built condition and it is acceptable.

Sincerely,

Paul W. Spears, PE



12/14/2016