

## **FIRE DEPARTMENT**

## PLAN REVIEW CONDITIONS

February 28, 2018

COOKIE JAR BAKERY 1005 SE 2ND TER LEES SUMMIT, MO 64063

| Permit No:       | PRCOM20180443   |
|------------------|---|
| Project Title:   | COOKIE JAR BAKERY                                     |
| Project Address: | 120 SW 3RD ST, LEES SUMMIT, MO 64063                  |
| Parcel Number:   | 6134023090000000                                      |
| Location:        | LEE'S SUMMIT TOWN OFLOTS 19 & 20 BLK 11 (EX PT IN RD) |
| Type of Work:    | CHANGE OF TENANT                                      |
| Occupancy Group: |   |
| Description:     | TENANT FINISH FOR BAKERY                              |

\*drawing is in plan review file

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

| Building Plan Review | Reviewed By: Joe Frogge | Pending  |
|----------------------|-------------------------|----------|
| Fire Plan Review     | Reviewed By: Joe Dir    | Reiected |

1. 2012 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building , each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

ACTION REQUIRED: (verified at inspection)

Numeric (120) address shall be readable from the roadway and posted on all doors leading into the business.

2. 2012 IFC 906.2- General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10. ACTION REQUIRED:(verified at inspection)

Provide a minimum of one 2A-10BC fire extinguisher. Extinguisher to be mounted on a wall on a normal path of travel close to an exit.

3. Door operation
ACTION REQUIRED:No keyed locks on the egress side of an exit
[B] 1008.1.9 Door operations. Except as specifically permitted by this section egress doors shall be readily openable from the egress side without the use of a key or special knowledge or effort.

4. Baking oven ACTION REQUIRED: Provide manufacturers information on the type of baking oven to be utilized.

5. Health DeptACTION REQUIRED:A Health Dept inspection will be required prior to opening to the public.

## The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.