



FIRE DEPARTMENT

PLAN REVIEW CONDITIONS

February 28, 2018

CMT CRAWFORD, MILLY & TILLY
211 NW EXECUTIVE WAY STE H
LEE'S SUMMIT, MO 64063

Permit No: PRCOM20180434
Project Title: LEES SUMMIT 2018 T-HANGAR PROJECT
Project Address: 2751 NE DOUGLAS ST, UNIT:X
Parcel Number:
Location: SEC 19 TWP 48 RNG 31 BEG NE COR OF SEC TH W 960' TH S 1600' TH W 360' TH S 1043' TH E
1320' TH N 2640' TO POB & N 1/2 VAC LEINWEBER RD LY S & ADJ
Type of Work: NEW COMMERCIAL
Occupancy Group:
Description: NEW 14 BAY AIRPLANE HANGAR

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review	Reviewed By: Joe Frogge	Pending
Fire Plan Review	Reviewed By: Joe Dir	Rejected

1. Emergency lighting

ACTION REQUIRED:

Provide emergency lighting for each hangar space and storage space.

[B] 1006.1 Illumination required. The means of egress, including the exit discharge, shall be illuminated at all times the building space served by the means of egress is occupied.

Exceptions:

1. Occupancies in Group U.
2. Aisle accessways in Group A.
3. Dwelling units and sleeping units in Groups R-1, R-2 and R-3.
4. Sleeping units of Group I occupancies.

[B] 1006.2 Illumination level. The means of egress illumination level shall not be less than 1 footcandle (11 lux) at the walking surface.

2. 2012 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building , each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

ACTION REQUIRED:(verified at inspection)

Provide Hangar building addressing, hangar space addressing and storage space labeling. Addressing shall be readable from the roadway.

3. 2012 IFC 906.2- General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

ACTION REQUIRED:(verified at inspection)

Provide one 2A-10BC fire extinguisher for each hangr space and storage area. Extinguishers are to be mounted on a wall close to an exit.

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.