

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFR20171746, Public Works Infrastructure Permit - Residential
Manor at Stoney Creek 2nd - street, storm, sewer and water

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Site Visit	Brice Lawson	Partial	Wednesday, February 28, 2018

Informational

- 1 Brice Lawson 02/26/2018 3:41 PM
I met with Jamie Kidwell and Thomas Hudgens to go over the ADA ramps, sidewalk and curb that has been installed at this site. They plan to make repairs and/or look into these issues.

Informational

- 2 Brice Lawson 02/28/2018 1:50 PM
Brice Lawson 02/28/2018 1:46 PM
Redford Construction is working on repairing the sags in the sanitary line segments. They have repaired and backfilled the four most west sags on the site.

Comments: