

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20174064, Public Works Infrastructure Permit - Commercial
COLEMAN EQUIPMENT

Address: 4101 NE LAKEWOOD WAY, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Sanitary - Material Verification	Jeremy Young	Partial	Wednesday, February 28, 2018

Informational

- 1 Jeremy Young 02/28/2018 3:17 PM Verified the materials that are to be used in the connection for the existing sanitary line. The Wye connection is SDR 26 and the pipe is also SDR 26 and manufactured within the last year. The fittings for the tie in are Fernco Strong Back fittings.

Comments: