

**PUBLIC WORKS ENGINEERING DIVISION**

## Inspection Summary

Permit #: PRPWFC20173845, Public Works Infrastructure Permit - Commercial

Scooters coffee

Address: 805 SW M 150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Erosion Sediment Control (ESC) Inspection	Matt Munger	Failed	Wednesday, February 28, 2018

Corrective Action Required

- 1 Matt Munger 02/28/2018 3:36 PM  
ESC was not in place due to the grading that was being done. I asked Sheldon to put up straw waddles since we are expecting rain overnight into the morning. I also advised him to place a gutter device in the curb inlet on the private side. He said he would take care of the ESC issues.

Comments: