

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20171689, Building Permit - Commercial

Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	John Borns	Partial	Thursday, March 01, 2018

Partial Correction

1	Misc	OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING SPACES/LOCATIONS: ROWS F THROUGH J, AND 17.3 THROUGH 16; STORAGE RM 1A226; RESTROOM 1A232; STORAGE RM 1A250; RESTROOM 1A217; CLEAN RM 1A218; EXTERIOR WALL AT 1A263 & 1A268; 261; 262.1; 262.2; 267; 218 COMPLETE; 263 COMPLETE; 210 COMPLETE; 258; 260; CORR 259; 209 S WALL; 213-215 E WALL; 266 N WALL; 266 W WALL B/F; 256 N WALL B/F; <b>[1A044 E; 1A200-203; 206-207; 256 S;</b>
---	------	---

<b>Underslab Plumbing Inspection - Commercial</b>	John Borns	Partial	Thursday, March 01, 2018
---	------------	---------	--------------------------

Partial Correction

1	Misc	OK TO COVER WHEN READY UNDER-SLAB PVC SANITARY DRAIN, WASTE, & VENT PIPING AT: 256 SUBSTERILE; PRE-OP AREA THREE LOCATIONS; <b>[1A264 FOR THREE STERLIZERS AND CART WASHER;</b>
---	------	---

NOTE IPC 312 / IRC P2503.5.1 REQUIREMENT FOR PRESSURE-TESTING PIPING SYSTEM.

Comments: