

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20172441, Building Permit - Residential

Address: 4721 NE GATEWAY DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Thursday, March 01, 2018

Corrective Action Required

1	Misc	-Provide full support under I beam end near the deck door. Install some squash block under the point load between the duct and the adjacent joist
---	------	--

****YOU CAN GO AHEAD AND ROCK THE AIN FLOOR. LEAVE THIS SPOT OPEN SO I CAN INSPECT**

Comments: