

---

**PUBLIC WORKS ENGINEERING DIVISION**

## **Inspection Summary**

---

Permit #: PRRES20173195, Building Permit - Residential

Address: 4705 NE POCONO CIR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection Item:

<b>Inspection:</b>	<b>Inspector:</b>	<b>Outcome:</b>	<b>Date:</b>
Driveway Inspection	Jeremy Young	Partial	Thursday, March 01, 2018

Informational

- 1 Jeremy Young 03/01/2018 2:36 PM inspected the pre-pour for the driveway. There appears to be at least 4" of compacted rock. The total driveway width is approx 35' which is within our specs. The contractor will add expansion joints while pouring.

**Comments:**

---