

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161771, Building Permit - Commercial

Address: 819 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Friday, March 02, 2018

Partial Correction

1 Misc

OK TO COVER WHEN READY 5/8" TYPE X GWB AT STAIRWELLS:

SOUTH STAIRWELL:

BASEMENT: 1ST LAYER INCLUDING PRE-ROCK; 2ND LAYER PRE-ROCK ONLY;

1ST FLOOR: 1ST LAYER INCLUDING PRE-ROCK; 2ND LAYER INCLUDING PRE-ROCK;

2ND FLOOR: 1ST LAYER INCLUDING PRE-ROCK; 2ND LAYER PRE-ROCK ONLY;

3RD FLOOR: 1ST LAYER INCLUDING PRE-ROCK; 2ND LAYER;

4TH FLOOR: 1ST LAYER INCLUDING PRE-ROCK; 2ND LAYER;

NORTH STAIRWELL:

BASEMENT: S & E WALLS - 1ST LAYER INCLUDING PRE-ROCK; S & E WALLS - 2ND LAYER; N & W WALLS - 1ST LAYER; N WALL - 2ND LAYER

1ST FLOOR: 2ND LAYER INCLUDING PRE-ROCK;

2ND FLOOR: 2ND LAYER PRE-ROCK ONLY;

3RD FLOOR: 1ST LAYER INCLUDING PRE-ROCK; 2ND LAYER;

4TH FLOOR: 1ST LAYER INCLUDING PRE-ROCK; 2ND LAYER;

Partial Correction

2 Misc

OK TO COVER WHEN READY 5/8" TYPE X GWB PRE-ROCK AT ELEVATOR:

BASEMENT: 1ST LAYER; 2ND LAYER

1ST FLOOR: 1ST LAYER; 2ND LAYER;

2ND FLOOR: 1ST LAYER; 2ND LAYER;

SHAFT FACE / LID: 1ST LAYER FULL HEIGHT; **[2ND LAYER FULL HEIGHT**

Partial Correction

3

Misc

SHAFT LID: **[3 LAYERS + HAT CHANNEL;**

OK TO COVER WHEN READY 5/8" TYPE X GWB AT:

BEHIND TUBS & SHOWERS

1ST LAYER FLOORS 4TH, 3RD, 2ND, 1ST, BASEMENT; [2ND LAYER
@ 4TH, 3RD, 2ND, 1ST, BASEMENT;

[SHEAR WALLS AT: BASEMENT 1ST LAYER; 1ST & 2ND LAYER AT
4TH, 3RD, 2ND, 1ST FLOORS;

Comments: