

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20174116, Building Permit - Commercial

Address: 318 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	John Borns	Failed	Monday, March 05, 2018

Corrective Action Required

2	Misc	NEW SHORT WALL NOT STEEL-FRAMED PER APPROVED DRAWING
---	------	--

Corrective Action Required

3	Misc	ICEMAKER WATER SUPPLY, BACKFLOW PREVENTION AND DRAIN NOT PIPED PER APPROVED DRAWING AND IPC.
---	------	--

Comments: