

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRRES20170715, Building Permit - Residential

Address: 3352 SW JESSIE LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Brice Lawson	Partial	Monday, March 05, 2018

Informational

- 1 Brice Lawson 03/05/2018 11:36 AM
The driveway approach forms are set. It appears that the rock has been compacted. It appears that a max. cross slope of 2% can be achieved where the sidewalk will run through the driveway approach.

Comments: