
PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRRES20172899, Building Permit - Residential

Address: 4705 NE GATEWAY DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Jeremy Young	Passed	Monday, March 05, 2018

Informational

1 Jeremy Young 03/05/2018 3:38 PM Inspected the driveway pour for the property. The cross slope between the sidewalk was between .04-1.8% which is within specs for ADA. There is a solid joint between the right of way and the other driveway. The contractor had placed the expansion joint between the curb and driveway.

Occupancy Inspection - Codes Residential	Mike Copeland	Not Ready	Monday, March 05, 2018
--	---------------	-----------	------------------------------

Corrective Action Required

1 DENIED DUE TO LACK OF EROSION CONTROL.

Erosion Control	Mike Copeland	Failed	Monday, March 05, 2018
-----------------	---------------	--------	------------------------------

Corrective Action Required

1 REQUESTED INSPECTION DENIED.
NO EROSION CONTROL IN PLACE.

Comments:

