

Inspection Summary

Permit #: PRCOM20170916, Building Permit - Commercial

Address: 2100 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mike Copeland	Partial	Tuesday, March 06, 2018
Partial Correction 1 Misc		LINE 6 (2 HOUR WALL) WITNESSED ASSEMBLY OF FIRE INSULATION AND SPRAY BETWEEN AIR GAP IN 2 HOUR WALL. -ROOF TOP FIRESTOP APPROVED	
Partial Correction 2 Misc		SOUTH MECHANICAL ROOM (2 HOUR): NORTH FACE, TOP OUT SCREW PATTERN APPROVED 1ST LAYER (TOP 6 FEET)	
Partial Correction 3 Misc		WEST ELEVATOR SHAFT: ALL APPROVED, 2nd LAYER FACE APPROVED	
Partial Correction 4 Misc		SOUTH STAIR TOWER, FIRST LAYER SHAFT WALL APPROVED, 2ND LAYER APPROVED, NEED TO INSPECT WHERE FRAMING AROUND LANDING AREA	
Partial Correction 5 Misc		ELEVATOR A, B: SHAFT WALL APPROVED, 2nd LAYER GYP BOARD APPROVED; SHAFT WALL AT FRONT FACE APPROVED	
Partial Correction 6 Misc		STAFF ELEVATOR 1: SHAFT WALL APPROVED; FIRST LAYER APPROVED; SECOND LAYER APPROVED	
Partial Correction 7 Misc		WEST STAIR: EAST WALL SHAFT, 1ST LAYER AND SECOND LAYER APPROVED. EAST SHAFT WALL APPROVED.	
Above Ceiling Inspection	Mike Copeland	Partial	Tuesday, March 06, 2018

CODES ADMINISTRATION

Partial Correction

1 Misc

-SOUTH STAIR 3-ST5 APPROVED TO DROP
-WEST WING CORRIDOR ALCOVE HARD LIDS APPROVED.
-2 NURSE STATIONS APPROVED
-SOILS ROOM APPROVED

[3-160; 161; 163; 165; 166; 167; 185; COR 7;

Partial Correction

2 Misc

SOUTH CORRIDOR:

LABEL SMOKE PARTIAN, NOT SMOKE BARRIOR.

Partial Correction

3 Misc

SOUTH PATIENT ROOMS APPROVED TO DROP TILE.

Comments: