

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20161765, Building Permit - Commercial

Address: 801 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Miscellaneous Inspection</b>	John Borns	Partial	Tuesday, March 06, 2018

Partial Correction

1

Misc

REFRIGERATOR RECEPTS OK

MW RECEPTACLES:

4TH FLR SW UNIT: RECEPT NOT IN BOX

4308: NO MW RECEPT FOUND. BOX COVERED?

**Comments:**