

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20174116, Building Permit - Commercial

Address: 318 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	John Borns	Partial	Wednesday, March 07, 2018

Corrective Action Required

1 Misc

STEEL-FRAMED SHORT WALL OK TO COVER AFTER MC CABLE IS STRAPPED WITHIN 12" OF ENTRY TO BOXES -- TWO LOCATIONS.

Corrective Action Required

2 Misc

ICEMAKER WATER SUPPLY, BACKFLOW PREVENTION AND DRAIN NOT PIPED PER APPROVED DRAWING AND IPC.

Comments: