

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20170916, Building Permit - Commercial

Address: 2100 SE BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

| Inspection:                     | Inspector:    | Outcome: | Date:                    |
|---------------------------------|---------------|----------|--------------------------|
| <b>Above Ceiling Inspection</b> | Mike Copeland | Partial  | Thursday, March 08, 2018 |

Partial Correction

1 Misc

-SOUTH STAIR 3-ST5 APPROVED TO DROP  
-WEST WING CORRIDOOR ALCOVE HARD LIDS APPROVED.  
-2 NURSE STATIONS APPROVED  
-SOILS ROOM APPROVED

[3-160; 161; 163; 165; 166; 167; 185; COR 7;

Partial Correction

2 Misc

SOUTH PATIENT ROOMS APPROVED TO DROP TILE AND HARD LIDS.

NORTH PATIENT ROOMS, HARD LIDS APPROVED. LABEL MED GAS AS DISCUSSED IN EAST 4 ROOMS.

WEST WING CORE, APPROVED TO DROP TILE IN ALL EXCEPT 134 AND 131

**Rated Assembly Inspection**

Mike Copeland

Partial

Thursday, March 08, 2018

Partial Correction

1 Misc

LINE 6 (2 HOUR WALL) WITNESSED ASSEMBLY OF FIRE INSULATION AND SPRAY BETWEEN AIR GAP IN 2 HOUR WALL.  
-ROOF TOP FIRESTOP APPROVED

Partial Correction

2 Misc

SOUTH MECHANICAL ROOM : NORTH FACE, TOP OUT SCREW PATTERN APPROVED 1ST LAYER (TOP 6 FEET)

Partial Correction

3 Misc

WEST ELEVATOR SHAFT: ALL APPROVED, 2nd LAYER FACE

Partial Correction  
4 Misc

APPROVED

SOUTH STAIR TOWER, FIRST LAYER SHAFT WALL APPROVED, 2ND LAYER APPROVED, NEED TO INSPECT WHERE FRAMING AROUND LANDING AREA

Partial Correction  
5 Misc

ELEVATOR A, B: SHAFT WALL APPROVED, 2nd LAYER GYP BOARD APPROVED;  
SHAFT WALL AT FRONT FACE APPROVED, FIRST LAYER GYP APPROVED, SECOND LAYER GYP APPROVED

Partial Correction  
6 Misc

STAFF ELEVATOR 1: SHAFT WALL APPROVED; FIRST LAYER APPROVED; SECOND LAYER APPROVED

Partial Correction  
7 Misc

WEST STAIR: EAST WALL SHAFT, 1ST LAYER AND SECOND LAYER APPROVED. EAST SHAFT WALL APPROVED.

**Comments:**