



## FIRE DEPARTMENT

### PLAN REVIEW CONDITIONS

March 08, 2018

COOKIE JAR BAKERY  
1005 SE 2ND TER  
LEES SUMMIT, MO 64063

Permit No: PRCOM20180443  
Project Title: COOKIE JAR BAKERY  
Project Address: 120 SW 3RD ST, LEES SUMMIT, MO 64063  
Parcel Number: 61340230900000000  
Location: LEE'S SUMMIT TOWN OF---LOTS 19 & 20 BLK 11 (EX PT IN RD)  
Type of Work: CHANGE OF TENANT  
Occupancy Group:  
Description: TENANT FINISH FOR BAKERY

\*drawing is in plan review file

***The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.***

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

#### **Fire Plan Review**

**Reviewed By: Joe Dir**

**Approved with Conditions**

1. 2012 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building , each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

ACTION REQUIRED: (verified at inspection)

Numeric (120) address shall be readable from the roadway

2. 2012 IFC 906.2- General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

ACTION REQUIRED:(verified at inspection)

Provide a minimum of one 2A-10BC fire extinguisher. Extinguisher to be mounted on a wall on a normal path of travel close to an exit.

3. Door operation

ACTION REQUIRED:(verified at inspection)

No keyed locks on the egress side of an exit

[B] 1008.1.9 Door operations. Except as specifically permitted by this section egress doors shall be readily openable from the egress side without the use of a key or special knowledge or effort.

**Building Plan Review**

**Reviewed By: Joe Frogge**

**Pending**

2. For the Health Department inspection contact Deb Sees with the Jackson County Public Works Department, Environmental Health Division at (816) 847-7070. Health Department approval is required prior to receiving any type of Occupancy from the City of Lee's Summit.

Action required: Comment is for informational purposes.

4. 2011 NEC 210.8 (B) Other Than Dwelling Units. All 125-volt, single-phase, 15- and 20-ampere receptacles installed in the locations specified in 210.8(B)(1) through (8) shall have ground-fault circuit-interrupter protection for personnel.

(1) Bathrooms

(2) Kitchens

(3) Rooftops

(4) Outdoors

(5) Sinks - where receptacles are installed within 6 feet of the outside edge of the sink.

(6) Indoor wet locations

(7) Locker rooms with associated showering facilities

(8) Garages, service bays, and similar areas where electrical diagnostic equipment, electrical hand tools, or portable lighting equipment are to be used.

(refer to code for exceptions)

Action required: All receptacles in kitchen area and within 6' of sinks (or similar) to be GFCI protected.  
3/7/18 - some, but not all receptacles have been designated as GFCI.

5. 2012 IMC 507.2 Where Required. A Type I or Type II hood shall be installed at or above all commercial cooking appliances in accordance with Sections 507.2.1 and 507.2.2. Where any cooking appliance under a single hood requires a Type I hood, a Type I hood shall be installed. Where a Type II hood is required, a Type I or Type II hood shall be installed. Exception: Where cooking appliances are equipped with integral down-draft exhaust systems and such appliances and exhaust systems are listed and labeled for the application in accordance with NFPA 96, a hood shall not be required at or above them.

Action required: Provide verification that oven does not require a hood.

7. MEP (hvac, electrical, plumbing) designs not provided.

Action required: Provide complete MEP design or detailed scopes of work from licensed professionals.  
3/7/18 - not completely addressed.

- provide pipe material schedule

***The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.***

***The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.***