

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRRES20173141, Building Permit - Residential

Address: 1308 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Jeremy Young	Passed	Thursday, March 08, 2018

Informational

- 1 Jeremy Young 03/08/2018 11:00 AM The contractor poured the driveway. The cross slope is between 0-1.0% through the driveway for ADA requirements. There is 6" of concrete and the expansion joints have been added.

DEI-Sidewalk Inspection	Jeremy Young	Passed	Thursday, March 08, 2018
-------------------------	--------------	--------	--------------------------------

Informational

- 1 Jeremy Young 03/05/2018 2:30 PM John DiMauro and I met the contractor on site. There was sufficient compacted rock base of at least 4". We verified the cross slopes of the sidewalk to comply with ADA standards. I will inspect after it is poured.

Informational

- 2 Jeremy Young 03/08/2018 11:04 AM The sidewalk is in compliance with ADA standards. The cross slope is 0-1% through all of the sidewalk. There is at least 4" of concrete for the sidewalk. It appears the correct concrete was used.

Comments: