

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20173999, Building Permit - Commercial

Address: 3540 SW HOLLYWOOD DR, Unit:4, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	Mike Copeland	Failed	Thursday, March 08, 2018

### Corrective Action Required

1	B1805.4.1 Design	FOOTINGS AND FOUNDATIONS. REBAR IS REQUIRED TO HAVE A MINIMUM OF 3" CLEARANCE FOR CONCRETE COVERAGE FROM STEEL
---	------------------	--

### Comments: