

CODES ADMINISTRATION

Temporary Certificate of Occupancy

Permit #:	PRCOM20170618
Address:	3201 SW FASCINATION DR, LEES SUMMIT, MO 64081
Inspected On:	Thursday, March 08, 2018
Inspected By:	Mark HardingMichael WeissenbachJennifer ThompsonCurtis DeasonSteve
	Robbins
Expiration Date:	5/29/2018 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:			
Occupancy Inspection - Codes Commercial	Mark Harding	Temporary C of O	Thursday, March 08, 2018			
Corrective Action Required:						
1 Misc	 health ok planning ok for TCO engineering ok for TC water ok for cofo Fire ok for COFO Codes ok for TCO 	0				
Occupancy Inspection - Fi	e Michael Weissenbach	Passed	Thursday, March 08, 2018			

220 SE Green Street | Lee's Summit, MO 64063 |816.969.1200 | 816.969.1201 Fax | cityofLS.net/Development

Occupancy Inspection - Planning	Jennifer Thompson	Temporary C of O	Thursday, March 08, 2018			
Corrective Action Required:						
1	General site clean up is needed (construction debris, machinery, roll-off containers, etc.)					
Corrective Action Required:						
2	Site restoration and grass is required to be established.					
Corrective Action Required:						
3	The front entry concrete area is still under construction.					
Corrective Action Required:						
4	Front entry landscaping was not complete.					
Corrective Action Required	J:					
5	A final determination is needed regarding the screening for the roof-top equipment. This final inspection will be at a later date.					
Occupancy Inspection - Water Utilities	Curtis Deason	Temporary C of O	Thursday, March 08, 2018			
Occupancy Inspection - Field Services	Steve Robbins	Temporary C of O	Thursday, March 08, 2018			
Corrective Action Required: 1 Misc pending punch list and final completion						