



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20173847	Date:	March 09, 2018
Project Title:	TROPICAL SMOOTHIE CAFE	Applicant:	
Location:	910 NW BLUE PKWY, Unit:B, LEES SUMMIT, MO 64086	KANSAS CITY FIRE AND SECURITY LLC 901 E LOULA ST OLATHE, KS 66061	
Type of Work:			
Occupancy Group:			
Description:	TENANT FINISH FOR SMOOTHIE CAFE (DEMISING WALL UNDER PERMIT PRCOM20173344)	Primary: (913) 780-5237	
Construction Type:	Type IIB (Unprotected)		
Map Page:	195A		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Joe Dir

Pending

1. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.