
PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRRES20173192, Building Permit - Residential

Address: 1687 NE PARKWOOD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Jeremy Young	Passed	Friday, March 09, 2018

Informational

- 1 Jeremy Young 03/09/2018 11:14 AM Contractor has poured the approach. There is at least 6" of concrete. The expansion joint has been added and the driveway is less than the 36' limit.

Comments:
