

Certificate of Occupancy

Permit #: PRCOM20174116
Address: 318 SW BLUE PKWY, LEES SUMMIT, MO 64063
Inspected On: Monday, March 12, 2018
Inspected By: John BornsMichael Weissenbach

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Full C of O	Monday, March 12, 2018
Occupancy Inspection - Fire	Michael Weissenbach	Passed	Monday, March 12, 2018

Comments:

- RESIDENTIAL SYLE WATER CLOSET SEAT TO BE REPLACED WITH OPEN FRONT COMMERCIAL TYPE.
- RECOMMEND CAPS ON UNUSED WATER SUPPLY STUBS IN SUPPLY ROOM.
- RECOMMEND CHECK WITH PLUMBING CONTRACTOR RE SEEPING TPR VALVE ON WATER HEATER.