

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFR20171420, Public Works Infrastructure Permit - Residential
CREEKSIDE AT RAINTREE

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Sanitary Sewer - Manhole Adjustment	Tom Chandler	Partial	Monday, March 12, 2018
Informational			
1	Tom Chandler 03/12/2018 Installed 32" barrel section on MH 1-B. Manhole needed to be lowered. Removed 42" barrel section.		
DEI-Miscellaneous PWORKS Inspection	Tom Chandler	Partial	Monday, March 12, 2018
Informational			
1	Tom Chandler 03/12/2018 Began installing underdrain. Cut trench and installed fabric and rock. Waiting for contractor to core into storm structure.		

Comments: