

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20170916, Building Permit - Commercial

Address: 2100 SE BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Mike Copeland	Failed	Tuesday, March 13, 2018

Corrective Action Required

1

ROOMS 166, 167, 185, SOUTH CORRIDOOR TO ELEVATOR ONLY:  
TWO RECEPTACLES NORTH OF SINK NEED GFCI.  
HORN STROBES CORRIDOOR AND IN ROOMS NEED ACTIVATED.

**Comments:**