

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20173421, Building Permit - Residential

Address: 612 NW OLIVE ST, Unit:A, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	John Borns	Partial	Tuesday, March 13, 2018

Corrective Action Required

2

IBC 718.2; IRC R502.13; R602.8 FIREBLOCKING: IN WOOD-FRAMED STRUCTURE FIRE-BLOCK ALL LEVEL-TO-LEVEL OPENINGS AND INTERSECTIONS OF VERTICAL AND HORIZONTAL CAVITIES. **ANY HOLES OR DISCONTINUITIES IN TOP & BOTTOM PLATES; INTERFACES OF WALLS WITH FLOOR/CEILING.**

ABOVE PERTAINS TO LOWER LEVEL AND, IF TO RECEIVE DRYWALL, UPPER LEVEL AS WELL. DO NOT INSULATE OR OTHERWISE COVER WALLS BEFORE SILL PLATE ANCHORAGE IS APPROVED.

ANCHOR BOLTS OK; ELECTRICAL WIRING OK

Comments: