Development Services Department

220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20172339, Building Permit - Commercial Address: 300 SW BLUE PKWY, Unit:D, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Occupancy Inspection - John Borns Partial Wednesday, March 14, 2018

Codes Commercial

Corrective Action Required

1 Misc ROOFTOP FINAL INSPECTION:

- REMOVE ABANDONED EQUIPMENT AND MATERIAL

- CONTACT HECTOR SOTO @ 816-969-1238 TO REQUEST LS PLANNING INSPECTION OF COMPLETED RTU SCREENING - RTU SCREENS ARE NOT SECURED TO ROOF STRUCTURE

- FINAL CLEAN ALL DEBRIS AND LOOSE MATERIAL FROM PLANET

FITNESS ROOFTOP FOOTPRINT

Corrective Action Required

3 Misc IFGC 407; 415: PROTECTION OF ROOF MEMBRANE UNDER

WOODEN PIPING SUPPORT BLOCKS FOR ROOFTOP EQUIPMENT

AND GAS PIPING: APPLY SPECIFIED / APPROVED,

ROOF-COMPATIBLE SLIP SHEET TO UNDERSIDE OF BLOCKS WITH

METAL FASTENERS AT SIDES OF BLOCKS.

SOME WOOD BLOCKS LACK SLIP SHEETS

Comments: