



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20173849	Date:	March 15, 2018
Project Title:	TAILOR MADE LANDING	Applicant:	
Location:	1610 SE HAMBLER RD, LEES SUMMIT, MO 64081	CONSOLIDATED FIRE PROTECTION 14130 NW DUGAN DR KANSAS CITY, MO 64152	
Type of Work:			
Occupancy Group:	MIX		
Description:	CONVERT BARN TO OFFICE/WAREHOUSE AND ADDITIONAL FUTURE TENANT SPACE	Primary: (816) 891-1099	
FOUNDATION PERMIT -	PRCOM20180059		
Construction Type:	Type IIB (Unprotected)		
Map Page:	195R		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Joe Dir

Released for Construction

1. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

ACTION REQUIRED:(information purposes)

All required field testing and acceptance testing shall be completed prior to the final occupancy inspection. Contact the fire department to schedule tests. (816)969-1300

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.