

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20180458, Building Permit - Commercial

Address: 3680 NE AKIN DR, Unit:114, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection - Commercial</b>	Khanh Nguyen	Failed	Thursday, March 15, 2018

Corrective Action Required

1

-INSTALL LABELING IDENTIFYING THE DISCONNECT WITH TENANT  
114

Comments: