

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20173173, Building Permit - Commercial

Address: 1150 NE DOUGLAS ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	John Borns	Partial	Thursday, March 15, 2018

Corrective Action Required

1

PENETRATIONS OF EXTERIOR WALLS TO BE SEALED

Corrective Action Required

2

- ELECTRICAL PANELS TO BE DESIGNATED ON FRONTS.  
- LABELING OF LEFT PANEL POSTION #41 TO BE CLARIFIED

Corrective Action Required

3

- FIRE DEPARTMENT ISSUES TO BE RESOLVED

Corrective Action Required

4

**OCCUPANCY STATUS: OK TO BRING CONTENTS AND SET UP FOR BUSINESS. NO PUBLIC OR CUSTOMERS BEFORE APPROVAL.**

Corrective Action Required

5

NOTED: LIGHT-GAUGE STEEL FRAMING AND ENCLOSED SYSTEMS AT WEST AND EAST CANOPIES WERE NOT REQUESTED FOR INSPECTION BEFORE COVERING. COMPOSITION / CONDITION ARE UNKNOWN.

<b>Occupancy Inspection - Fire</b>	Michael Weissenbach
------------------------------------	---------------------

Temporary C of O

Thursday, March 15, 2018

Comments: