Development Services Department

220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20173708, Building Permit - Residential Address: 206 SW 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Plumbing Inspection - Residential	John Borns	Partial	Monday, March 19, 2018
Corrective Action Require 1 Miscellaneous	Correction TWO T VACU	T HREADED HOSE BIBS AT B J M BREAKERS. THER ISSUES.	ASEMENT NEED SCREW-ON
Rough Plumbing Inspection - Residential	John Borns	Passed	Monday, March 19, 2018

Comments: CALL FOR RE-INSPECTION WHEN READY.