

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRRES20173920, Building Permit - Residential

Address: 206 SW 3RD ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection: Inspector: Outcome: Date:

**Final Mechanical** John Borns Failed Monday, March 19, 2018  
**Inspection - Residential**

Corrective Action Required

1 Miscellaneous Correction IRC R703.1 SEALING OF EXTERIOR WALL: SEAL WALL WHERE LINE SETS PENETRATE.

Corrective Action Required

2 Miscellaneous Correction NEC 350.30; IRC 3802.1: LIQUIDTIGHT FLEXIBLE NON-METALLIC ELECTRICAL WHIP MUST BE SECURED TO STRUCTURE WITHIN 12" OF ENTRY TO A/C DISCONNECT ENCLOSURE. ZIP-TYING TO LINESET DOES NOT SATISFY ELECTRICAL CODE REQUIREMENT.

**Rough Mechanical** John Borns Passed Monday, March 19, 2018  
**Inspection - Residential**

**Comments:**