
PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20173845, Public Works Infrastructure Permit - Commercial

Scooters coffee

Address: 805 SW M 150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Storm - Outlet Structure	Matt Munger	Failed	Monday, March 19, 2018

Corrective Action Required

1 Matt Munger 03/19/2018 3:26 PM

The NW flume that was installed to drain the rain run off from the parking lot into the ditch off M150 appears to be holding water.

Comments:
