
PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20173845, Public Works Infrastructure Permit - Commercial

Scooters coffee

Address: 805 SW M 150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Storm - Swales	Matt Munger	Passed	Tuesday, March 20, 2018

Informational

1 Matt Munger 03/20/2018 10:54 AM

I had taken a picture of the drainage from the flume to the swale on 3/19/18 since we had rain in excess of an inch that day. I spoke with Dan Harper in regards to my concern with the NW flume/swale and he stated it was a little bit of concern but it was draining and would be ok.

DEI-Storm - Outlet Structure	Matt Munger	Passed	Tuesday, March 20, 2018
------------------------------	-------------	--------	-------------------------------

Corrective Action Required

1 Matt Munger 03/19/2018 3:26 PM

The flume that was installed to drain the rain run off from the parking lot into the ditch off M150 appears to be holding water.

Informational

2 Matt Munger 03/20/2018 10:54 AM

I had taken a picture of the drainage from the flume to the swale on 3/19/18 since we had rain in excess of an inch that day. I spoke with Dan Harper in regards to my concern with the NW flume/swale and he stated it was a little bit of concern but it was draining and would be ok.

Comments:

