

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20180443, Building Permit - Commercial

Address: 120 SW 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Passed	Tuesday, March 20, 2018

Comments: AFTER 4 SHIELD PLATES AND ONE BOCA PLATE ARE INSTALLED AT LOCATIONS POINTED OUT OK TO CLOSE NEW WALLS AND EXISTING WALL AREAS OPENED FOR MODIFICATIONS. PONY WALLS ARE TO BE STABILIZED BY FIXED BASE CABINETS.