

**PUBLIC WORKS ENGINEERING DIVISION**

## Inspection Summary

Permit #: PRPWFC20173611, Public Works Infrastructure Permit - Commercial

Village at View High On-Site Infrastructure

Address: 3390 NW VILLAGE PARK DR, LEES SUMMIT, MO 640813391 NW VILLAGE PARK DR, LEES SUMMIT, MO 64081245 NW KESSLER DR, LEES SUMMIT, MO 64081201 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Water Line - Coliform Test 2	Steve Robbins	Passed	Wednesday, March 21, 2018

Informational

1 Matt Munger 03/15/2018 9:44 AM  
Casey took two samples, I delivered the samples to Blue Valley Labs.

Informational

2 I was out at classes on the 15, and 16. and I was out sick on the 19, and the 20th. While i was out the sample I took to the lab and the sample Matt took to the lab have both passed. This completes the samples for the new water line on viewhigh. They have not tied in to the main yet.Steve Robbins 03/21/2018 11:42 AM

Comments: