

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRRES20173776, Building Permit - Residential

Address: 1713 NE PARKWOOD DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Failed	Thursday, March 22, 2018

### Corrective Action Required

1	Miscellaneous Correction	FRAMING: -Have engineer check roof support beam size above front bed -Plan calls for triple LVL beam below foyer.
---	--------------------------	---

**\*\*OK TO INSULATE**

### Comments: