

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRRES20173776, Building Permit - Residential

Address: 1713 NE PARKWOOD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Jeremy Young	Partial	Thursday, March 22, 2018

Informational

1 Jeremy Young 03/22/2018 11:45 AM Contractor has sufficient compacted rock at least 4" there is a clean joint at the ROW line. The cross slope for the ADA requirements are between .05-1.0%. There will be at least 6" of concrete for the ROW.

All Rough Inspection - Residential	Khanh Nguyen	Failed	Thursday, March 22, 2018
---------------------------------------	--------------	--------	--------------------------------

Corrective Action Required

1 FRAMING:
-Have engineer check roof support beam size above front bed
-Plan calls for triple LVL beam below foyer.

****OK TO INSULATE**

Comments: