Development Services Department

220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20170784, Building Permit - Commercial Address: 3621 NE AKIN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

In-wall Inspection Khanh Nguyen Failed Thursday, March 22, 2018

Corrective Action Required

Miscellaneous Correction **IN-WALL ONLY FROM CORRIDOR/OPEN OFFICE WALL TO

SOUTH EXTERIOR WALL:

-ALL EXTERIOR WALL BOTTOM TRACK SHALL BE ANCHORED TO

FOOTING PER PLAN (1/2" BOLT @ 32" OC)

-ALL EXTERIOR STUDS SHALL BE FASTENED TO UPPER SUPPORT L

STEEL PER PLAN (3 SCREWS AT SLOTS AND 4 TO L STEEL)

-ALL EXTERIOR WINDOW HEADERS SHALL BE SIZED PER PLAN (8"

FOR H1 AND 12" OF H2); INSTALL 2 KINGS STUDS, 1 CRIPPLE

STUD, AND FASTENED TOGETHER PER DETAIL

-PROTECT PVC AT BOTTOM TRACK

-COMPLETE PLUMBING AT NEAR SW OF BUILDING

Comments: