Development Services Department

220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20173727, Building Permit - Residential Address: 206 SW 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Final Electrical John Borns Failed Friday, March 23, 2018

Inspection - Residential

Corrective Action Required

E3802.5 Unfinished GFCI PROTECTION. All 125-volt, single-phase, 15- and 20-ampere

basement receptacles receptacles installed in unfinished basements shall have

ground-fault circuit-interrupter protection for personnel. SEE

RECEPTACLE OVERHEAD AT BASEMENT SOUTH.

Comments: