

Temporary Certificate of Occupancy

Permit #: PRRES20162330
Address: 1308 NE BRANDYWINE RD, LEES SUMMIT, MO 64064
Inspected On: Friday, March 23, 2018
Inspected By: Khanh Nguyen
Expiration Date: 4/23/2018 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Temporary C of O	Friday, March 23, 2018

Corrective Action Required:

- | | | |
|---|-----------------------------|---|
| 1 | Miscellaneous
Correction | -WATER SERVICE: SHALL CLEAN MUD OFF THE WATER SERVICE; FILL
BOTTOM OF PIT WITH GRAVEL PER CITY STANDARD

-INSTALL SECURITY STRIKE PLATE FOR THE DECK DOOR

-LOOP UP AND SECURE THE DISH WASHER DRAIN;

-SUPPORT EXPANSION TANK
**I NEED TO SEE THE INSTALLATION MANUAL OF THE EXPANSION
TANK |
|---|-----------------------------|---|